

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00836

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Product(s): SF4100 Range of Photoelectric Smoke Alarms with Wireless Interconnect
(refer to attached appendix for details and conditions)

Placed on the market under the name or trade mark of: Somfy Activites SA
50 Avenue du Nouveau Monde
74300 Cluses
France

and produced in the manufacturing plant(s): Siterwell Electronics Co. Ltd. (SG- 15306)
No. 666 Qingfeng Road, Jiangbei District
Ningbo, Zhejiang Province
P. R. China

Intended use: Fire Safety

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 14604:2005+AC:2008

Under System 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

This certificate was first issued under **0359-CPR-00836** on **2019-09-10** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Notified Body

0905

Certification Manager: Diph-Ing. Roland Heine

Date Issue: 2020-11-12

Issue: 1

Signature:



This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00836

APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00836

The details and conditions of use for the SF4100 Range of Photoelectric Smoke Alarms with Wireless Interconnect, placed on the market under the name or trade mark of:

Somfy Activites SA
50 Avenue du Nouveau Monde
74300 Cluses
France

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Products compliant with EN 14604:2005+AC:2008

Model	Manufacturing Location	Description
SF4100	SG-15306	Photoelectric Smoke Alarm with Wireless Interconnect (868MHz)

Conditions of use:

Suitable for indoor applications only

Approved settings:

Batteries:

2 x 1.5 V Alkaline AA batteries, as listed below:

Manufacturer	Model No.
Energizer	E91
Gold Peak Group	GP15A
Zhejiang Mustang Battery Co., Ltd.	Raymax LR6

General Notes:

1. Evaluated under Intertek project number G103876234.
2. The SF4100 Photoelectric Smoke Alarms have not been approved for installation into leisure accommodation vehicles (LAVs).
3. Radio frequency capabilities of smoke alarms are outside the scope of EN14604:2005+AC:2008; the wireless interconnect (radio-link) function of the SF4100 Photoelectric Smoke Alarms, is therefore not covered by this approval.
4. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.